




## Pump Specification

### FL100-Series

### 1 hp Submersible Effluent Pumps



## FL100-Series Dimensional Data



## FL100-Series Electrical Data

MODEL	HP	VOLTAGE	PHASE	SF	FULL LOAD AMPS	LOCKED ROTOR AMPS	THERMAL OVERLOAD TEMP	STATOR WINDING CLASS	CORD LENGTH [FT]	DISCHARGE [IN]	AUTOMATIC
FL102M-2	1	208-230	1	1.00	12	28.5	120°C / 248°F	B	25	1-1/2 OR 2	NO
FL102M-3	1	208-230	1	1.00	12	28.5	120°C / 248°F	B	35	1-1/2 OR 2	NO
FL102A-2	1	208-230	1	1.00	12	28.5	120°C / 248°F	B	25	1-1/2 OR 2	YES
FL102A-3	1	208-230	1	1.00	12	28.5	120°C / 248°F	B	35	1-1/2 OR 2	YES
FL103M-2	1	208/230	3	1.00	9	32.1	N/A	B	25	1-1/2 OR 2	NO
FL103M-3	1	208/230	3	1.00	9	32.1	N/A	B	35	1-1/2 OR 2	NO
FL103M-5	1	208/230	3	1.00	9	32.1	N/A	B	50	1-1/2 OR 2	NO
FL104M-2	1	440-480	3	1.00	4.5	16	N/A	B	25	1-1/2 OR 2	NO
FL104M-3	1	440-480	3	1.00	4.5	16	N/A	B	35	1-1/2 OR 2	NO
FL104M-5	1	440-480	3	1.00	4.5	16	N/A	B	50	1-1/2 OR 2	NO
FL105M-2	1	575	3	1.00	3.3	13	N/A	B	25	1-1/2 OR 2	NO
FL105M-3	1	575	3	1.00	3.3	13	N/A	B	35	1-1/2 OR 2	NO
FL105M-5	1	575	3	1.00	3.3	13	N/A	B	50	1-1/2 OR 2	NO

## FL100-Series Control Panel Information

PUMP MODEL	SX-SERIES 3-FLOAT NEMA 1	SX-SERIES 3-FLOAT NEMA 4X	AE-SERIES 3-FLOAT NEMA 1	AE-SERIES 4-FLOAT NEMA 1	AE-SERIES 3-FLOAT NEMA 4X	AE-SERIES 4-FLOAT NEMA 4X	IPS-SERIES	IPD-SERIES
	SIMPLEX		DUPLEX				SIMPLEX	DUPLEX
FL102	SXL21=3	SXL24=3	AE21L=3	AE21L=4	AE24L=3	AE24L=4	IPS-24L	IPD-24L
FL103	—	SX34=3-191	—	—	AE34=3-191	AE34=4-191	IPS-34-191	IPD-34-191
FL104	—	SX34=3-171	—	—	AE34=3-171	AE34=4-171	IPS-34-171	IPD-34-171
FL105	—	SX54=3-151	—	—	AE54=3-151	AE54=4-151	IPS-54-151	IPD-54-151

## FL100-Series Technical Data

---

IMPELLER	2 VANE CLASS 25 CAST IRON
SOLIDS HANDLING	3/4"
PAINT	POWDER COATING
MAX LIQUID TEMP	
CONTINUOUS DUTY	40°C / 104°F
INTERMITTENT	60°C / 140°F
MAX STATOR TEMP	130°C / 266°F
THERMAL OVERLOAD	1-PHASE - 120°C / 248°F
POWER CORD TYPE	
1-PHASE	SJOOW
3-PHASE	SEOOW
MOTOR HOUSING	CLASS 25 CAST IRON
VOLUTE	CLASS 25 CAST IRON
SHAFT	STAINLESS
HARDWARE	STAINLESS
O-RINGS	BUNA-N
MECHANICAL SEAL	CARBON CERAMIC
WEIGHT	32.7 KG / 72 LB
CERTIFICATIONS	SSPMA, cCSAus

# ***FL100-Series Specifications***

---

## **1.01 GENERAL**

The contractor shall provide labor, material, equipment, and incidentals required to provide \_\_\_\_\_ (QTY) centrifugal effluent pumps as specified herein. The pump models covered in this specification are FL100-Series single or three-phase effluent pumps. The pump furnished for this application shall be model \_\_\_\_\_ as manufactured by Liberty Pumps.

## **2.01 OPERATING CONDITIONS**


Each submersible pump shall be rated at 1 hp, \_\_\_\_\_ volts, \_\_\_\_\_ phase, 60 Hz, 3450 RPM. The unit shall produce \_\_\_\_\_ GPM at \_\_\_\_\_ feet of total dynamic head.

The submersible pump shall be capable of handling 3/4" solids enabling pumping over long distances in pipelines as small as 1-1/2" in diameter. The submersible pump shall have a shut-off head of 90 feet and a maximum flow of 98 GPM @ 15 feet of total dynamic head.

The pump shall be controlled with:

- \_\_\_\_\_ A piggyback style on/off float switch
- \_\_\_\_\_ A NEMA 4X simplex control panel with three float switches including a high water alarm
- \_\_\_\_\_ A NEMA 4X duplex control panel with three float switches including a high water alarm

## **3.01 CONSTRUCTION**

Each centrifugal effluent pump shall be equal to the  Certified FL100-Series effluent pumps as manufactured by Liberty Pumps, Bergen NY. The castings shall be constructed of class 25 cast iron. The motor housing shall be oil-filled to dissipate heat. Air-filled motors shall not be considered equal since they do not properly dissipate heat from the motor. All mating parts shall be machined and sealed with a Buna-N O-ring. All fasteners exposed to the liquid shall be stainless steel. The motor shall be protected on the top side with sealed cord entry plate with molded pins to conduct electricity eliminating the ability of water to enter internally through the cord. The motor shall be protected on the lower side with a dual seal arrangement. The first seal is a double lip seal molded in FKM fluoroelastomer or Buna-N. The second/main seal shall be a unitized hard face carbon ceramic seal with stainless steel housings and spring.

The upper and lower bearing shall be capable of handling all radial thrust loads. The lower bearing shall have the additional ability to handle the downward axial thrust produced by the impeller. The pump housing shall be of the concentric design thereby equalizing the pressure forces inside the housing which will extend the service life of the seals and bearings. The pump shall be furnished with stainless steel handle having a nitrile grip.

## **4.01 ELECTRICAL POWER CORD**

The submersible pump shall be supplied with 25, 35 or 50 feet of multi-conductor power cord, as per **Electrical Data** table. It shall be cord type SJOOW or SEOW, capable of continued exposure to the pumped liquid. The power cord shall be sized for the rated full load amps of the pump in accordance with the National Electric Code. The power cord shall not enter the motor housing directly but will conduct electricity to the motor by means of a watertight compression fitting cord plate assembly with molded pins to conduct electricity. This will eliminate the ability of water to enter internally through the cord by means of a damaged or wicking cord.

## **5.01 MOTORS**

---

Single-phase motors shall be oil-filled, permanent split capacitor, class B insulated NEMA B design, rated for continuous duty. Three-phase motors shall be polyphase. At maximum load the winding temperature shall not exceed 130°C un-submerged. Since air-filled motors are not capable of dissipating heat they shall not be considered equal. The single-phase pump motor shall have an integral thermal overload switch in the windings for protecting the motor.

## **6.01 BEARINGS AND SHAFT**

---

Upper and lower radial bearings shall be required. The bearings shall be a single ball/race type bearing designed to handle axial pump thrust loads. Both bearings shall be permanently lubricated by the oil that fills the motor housing. The motor shaft shall be made of 17-4 PH stainless steel and have a minimum diameter of 0.625".

## **7.01 SEALS**

---

The pump shall have a dual seal arrangement consisting of a lower and upper seal to protect the motor from the pumping liquid. The lower seal shall be a FKM fluoroelastomer or Buna-N molded double lip seal designed to exclude foreign material away from the main upper seal. The upper seal shall be a unitized carbon ceramic hard face seal with stainless steel housings and spring. The motor plate/housing interface shall be sealed with a Buna-N O-ring.

## **8.01 IMPELLER**

---

The impeller shall be a class 25 cast iron 2 vane impeller, with pump out vanes on the back shroud to keep debris away from the seal area. It shall be screw mounted to the motor shaft with a bonding agent.

## **9.01 CONTROLS**

---

All single-phase units can be supplied with CSA and UL approved automatic wide-angle tilt float switches. The switches shall be equipped with piggyback style plug that allows the pump to be operated manually without the removal of the pump in the event that a switch becomes inoperable. Manual pumps are operable by means of a pump control panel.

## **10.01 PAINT**

---

The exterior of the casting shall be protected with powder coat epoxy or polyester paint.

## **11.01 SUPPORT**

---

The pump shall have cast iron support legs enabling it to be a freestanding unit. The legs will be high enough to allow 3/4" solids handling.

## **12.01 SERVICEABILITY**

---

Components required for the repair of the pump shall be shipped within a period of 24 hours.

### **13.01 FACTORY ASSEMBLED TANK SYSTEMS WITH GUIDE RAIL AND QUICK DISCONNECT DISCHARGE**

- Factory mounted guide rail system with pump suspended by means of thread-on quick disconnect which is sealed by means of nitrile grommets or O-rings. The discharge piping shall be Schedule 80 PVC and furnished with a check valve and PVC shut-off ball valve. The tank shall be wound fiberglass or roto-molded plastic. An inlet hub shall be provided with the fiberglass systems.
- Stainless steel guide rail
- Zinc plated steel guide rail
- Diameter of basin in inches
- Height of basin in inches
- Distance from top of tank to discharge pipe outlet in inches
- Fiberglass cover
- Structural foam polymer cover
- Steel cover
- Simplex system with outdoor panel and alarm
- Duplex system with outdoor panel and alarm
- Separate outdoor alarm
- Remote outdoor alarm

### **14.01 TESTING**

The pump shall have a ground continuity check and the motor chamber shall be hi-potted to test for electrical integrity, moisture content and insulation defects. The motor and volute housing shall be pressurized and an air leak decay test performed to ensure integrity of the motor housing. The pump shall be monitored for run voltage and current, and checked for noise or other malfunction.

### **15.01 QUALITY CONTROL**

The pump shall be manufactured in an ISO 9001 certified facility.

### **16.01 WARRANTY**

Standard limited warranty shall be 3 years.